





DIESEL GENERATOR FUEL OPTIMISED

ELECTRICAL											
			Prime Standby								
	Frequency (Hz)	Phases	Voltage (V)	kVA	kW	kVA	kW	MCB Rating (A)	Minimum ATP Rating (A)	Rated Speed (RPM)	
	50	2	400/2301/	180 0	144 0	198.0	1504	320	3.20	1500	

POWER FACTOR	
3 Phase	0.8
I Phase	

MAXIMUM LOAD IMPACT*		
kVA	108.00	
kW	86.40	

^{*}With 20% voltage and 10% frequency deviation @ 50Hz, 400V

ALL RATINGS ARE TO STANDARD REFERENCE CONDITIONS ISO 8528

Prime: This rating is for the supply of continuous electrical power, at variable load, in lieu of commercially purchase power. There is no limitation on the annual hours of operation and 10% over load power can be supplied for 1 hour in 12.

Standby: This rating is for the supply of continuous electrical power, at variable load, in the event of a utility power failure. No overload is permitted.

Stage IIIa models are only emissions compliant at 50Hz Prime Power in accordance with 97-68EC.



CANOPY/SKID	
Lockable Maintenance Access Doors	X
Control Panel Viewing Window	X
Fork Pockets	Δ
Single Lift Point	X
Bunding	Δ
Open Frame	•
High Density Fire Retardant Foam	X
Yellow Paint	X
White Paint	X
Standard: • Not Available: x Optional: A	Δ

ALTERNATOR ECO38 ISN/4		
Poles	4	
Winding Connections	Star	
Insulation	Class H	
Enclosure	IP23	
Exciter System	Self-regulating brushless	
Voltage Regulator	AVR	
Steady State Voltage Regulation	+/- 1.5%	
Bearing	Single bearing sealed	
Coupling	Flexible disc	
Cooling	Direct drive centrifugal blower fan	
Coating	Winding Protection Grey	

STARTING SYSTEM				
Starter Motor	kW	4.00		
Battery Capacity	Ah	110		
Number of Batteries		2		
Auxiliary Voltage	V	24		

ENGINE			
	1500 R	PM	
Output Rating (PRP)	kW	156.00	
Output Rating (Standby)	kW	172.04	
Manufacturer and Model		JCB 6 CYLINDER	
Fuel		Diesel	
Injection		Direct	
Aspiration		Turbo Charged	
Cylinders		6	
Bore and Stroke	mm	106 x 135	
Displacement	L	7.15	
Cooling		Water	
Engine Oil Specification		API CF-4	
Compression Ratio		16.9 : 1	
Engine Oil Capacity	L	28.00	
Coolant Capacity	L	26.00	
Governor		Electronic	
Air Filter		Two stage with restriction indicator	
Engine Oil Consumption	100% Load	0.1% of fuel consumed	
FUEL SYSTEM			
Diesel Specification		EN590	
Standard Fuel Tank Capacity	L	360	



FUEL CONSUMPTION					
100% Load Prime		L/h			38.00
75% Load Prime		L/h			29.60
50% Load Prime		L/h	50Hz		20.80
100% Load Standby		L/h			41.00
EXHAUST SYSTEM					
Maximum Temperature 100%	Standby	°C			465.00
Exhaust Gas Flow 100% Stanc	by	m ^{3/} min	50Hz	50Hz	26.50
Maximum Allowed Back Pressure		mbar			64.00
Exhaust Flange Size		mm		76.5	
AIR SYSTEM					
Intake Air Flow 100% Standby		m³/h			632.00
Total Cooling Air Flow 100% Standby		m^3/s	50Hz		2.47
Alternator Fan Airflow		m³/s			0.53
SOUND PRESSURE (CANOPY ONLY)					
LpA (7m)	50Hz		dB(A)		0

MECHANICAL FEATURES	
Cooling Pack	•
Air Filter	•
Mechanical Governor	•
Low Oil Pressure Switch	•
Coolant Temperature Sender	•
Oil Temperature Sender	•
Radiator Guards	•
Hot Component Guards	Δ
Manual Oil Drain Pump (Canopy)	Δ
Water Jacket Heater	Δ
Pre-Filter with Separator	•
Fuel Level Sender	•
Internal Fuel Fill (Belly Tank)	•
3 Way Fuel Valve	Δ
Residential Silencer	•
Industrial Silencer	×
Standard: ● Not Available: x	Optional: Δ



AVR DSR AVR DER Winding Protection Standard Winding Protection Standard + Winding Protection Grey Winding Protection Total Winding Protection Total + MAUX PMG Anti-Condensation Heater 3 Pole Moulded Case Circuit Breaker 4 Pole Moulded Case Circuit Breaker 5 Preparation for Earth Spike Optional Voltages Remote Screen Emergency Stop Button	ELECTRICAL FEATURES	
Winding Protection Standard x Winding Protection Standard + x Winding Protection Grey • Winding Protection Total Δ Winding Protection Total + Δ MAUX • PMG Δ Anti-Condensation Heater Δ 3 Pole Moulded Case Circuit Breaker • 4 Pole Moulded Case Circuit Breaker Δ Earth Leakage Protection (Shunt Trip) Δ Preparation for Earth Spike • Optional Voltages Δ Remote Screen Δ	AVR DSR	•
Winding Protection Standard + x Winding Protection Grey • Winding Protection Total Δ Winding Protection Total + Δ MAUX • PMG Δ Anti-Condensation Heater Δ 3 Pole Moulded Case Circuit Breaker • 4 Pole Moulded Case Circuit Breaker Δ Earth Leakage Protection (Shunt Trip) Δ Preparation for Earth Spike • Optional Voltages Δ Remote Screen Δ	AVR DER	×
Winding Protection Grey Φ Winding Protection Total Δ Winding Protection Total + Δ MAUX Φ PMG Δ Anti-Condensation Heater Δ 3 Pole Moulded Case Circuit Breaker Φ 4 Pole Moulded Case Circuit Breaker Δ Earth Leakage Protection (Shunt Trip) Δ Preparation for Earth Spike Φ Optional Voltages Δ Remote Screen Δ	Winding Protection Standard	×
Winding Protection Total Δ Winding Protection Total + Δ MAUX • PMG Δ Anti-Condensation Heater Δ 3 Pole Moulded Case Circuit Breaker • 4 Pole Moulded Case Circuit Breaker Δ Earth Leakage Protection (Shunt Trip) Δ Preparation for Earth Spike • Optional Voltages Δ Remote Screen Δ	Winding Protection Standard +	X
Winding Protection Total + Δ MAUX PMG Anti-Condensation Heater 3 Pole Moulded Case Circuit Breaker 4 Pole Moulded Case Circuit Breaker 5 Anti-Leakage Protection (Shunt Trip) Preparation for Earth Spike Optional Voltages Remote Screen Δ	Winding Protection Grey	•
MAUX • PMG Δ Anti-Condensation Heater Δ 3 Pole Moulded Case Circuit Breaker • 4 Pole Moulded Case Circuit Breaker Δ Earth Leakage Protection (Shunt Trip) Δ Preparation for Earth Spike • Optional Voltages Δ Remote Screen Δ	Winding Protection Total	Δ
PMG Δ Anti-Condensation Heater Δ 3 Pole Moulded Case Circuit Breaker • 4 Pole Moulded Case Circuit Breaker Δ Earth Leakage Protection (Shunt Trip) Δ Preparation for Earth Spike • Optional Voltages Δ Remote Screen Δ	Winding Protection Total +	Δ
Anti-Condensation Heater 3 Pole Moulded Case Circuit Breaker 4 Pole Moulded Case Circuit Breaker Δ Earth Leakage Protection (Shunt Trip) A Preparation for Earth Spike Optional Voltages A Remote Screen Δ	MAUX	•
3 Pole Moulded Case Circuit Breaker 4 Pole Moulded Case Circuit Breaker Δ Earth Leakage Protection (Shunt Trip) Δ Preparation for Earth Spike Optional Voltages Λ Remote Screen Δ	PMG	Δ
4 Pole Moulded Case Circuit Breaker Δ Earth Leakage Protection (Shunt Trip) Δ Preparation for Earth Spike \bullet Optional Voltages Δ Remote Screen Δ	Anti-Condensation Heater	Δ
Earth Leakage Protection (Shunt Trip) Δ Preparation for Earth Spike \bullet Optional Voltages Δ Remote Screen Δ	3 Pole Moulded Case Circuit Breaker	•
Preparation for Earth Spike \bullet Optional Voltages Δ Remote Screen Δ	4 Pole Moulded Case Circuit Breaker	Δ
Optional Voltages Δ Remote Screen Δ	Earth Leakage Protection (Shunt Trip)	Δ
Remote Screen Δ	Preparation for Earth Spike	•
	Optional Voltages	Δ
Emergency Stop Button	Remote Screen	Δ
0 / 1	Emergency Stop Button	•
External Emergency Stop Button	External Emergency Stop Button	•
Standard: $ullet$ Not Available: x Optional: Δ	Standard: • Not Available: x Optional: A	Δ

BATTERY FEATU	JRES		
Battery Isolator			Δ
Battery Type			Lead Acid
Battery Size (Ah)			110
Number of Batteries	S		2
Battery Charger			Δ
	Standard: ●	Not Available: x	Optional: Δ

JCB COMMUNICATION AN	D CONTROL				
4510		x			
4520		•			
Standard: ●	Not Available: x	Optional: Δ			
WEIGHT AND DIMENSIONS	3				
Length	mm	3800			
Width	mm	1100			
Height	mm	2000			
Shipping Volume (sea ready)	m^3	8.36			
Weight*	Kg	2270.00			
*Standard build with all fluids except fuel					
CE PACK (OPTIONAL)					
EMC Certification		•			
Hot Guards		•			
Belt Guards		•			
Earth Leakage Relay		•			
Sound Power Decal		x			
EU Declaration for Engine Emissions •					
Complete Machine Declaration of Conformity					
Standard: ●	Not Available: x	Optional: Δ			

REFERENCE STANDARDS

JCB Generators are CE certified and conform to the following Directives (subject to a country requiring such standard):

- EN 12100, EN13857, EN60204
- 2006/42/CE Machinery safety
- 2006/95/EC Low voltage
- 2004/I 08/CE Electromagnetic compatibility
- 2000/14/EC Sound Power Level (amended by 2005/88/EC)
- 97/68/EC Emissions(amended by 2002/88/EC & 2004/26/EC)
- Power according to ISO 8528 and ISO 3046
- Ambient reference conditions 1000mbar, 25°C, 30% relative humidity ISO3046
 Information based on standard specification equipment unless otherwise stated.